





MODEL SP345




SECTION A



SECTION B



SECTION C JAMB MULLION TYPE U FRAME
 SECTION D INTERLOCKED MULLION TYPE VM
 SECTION G INTERMEDIATE SUPPORT TYPE IS
 SECTION E CONCEALED MULLION TYPE CM
 SECTION F JAMB MULLION TYPE F FRAME



SP345 SPECIFICATIONS

BLADES HIGH PERFORMANCE DRAINABLE

ASSEMBLY - S/S MECHANICAL STANDARD
 WELDED OPTIONAL

FRAME DRAIN CHANNEL TYPE D
 DRAIN FLANGE TYPE F

EXTRUDED ALUMINUM 6063-T52 FRAME .080(2mm)

BLADE .080(2mm)

MULLIONS - VISIBLE MULLION TYPE VM
 CONCEALED MULLION TYPE CM
 INTERMEDIATE SUPPORT TYPE IS

SCREENS - ALUM. TYPE A
 1/2" X 1/2" .063 WIRE
 C/W FRAME

- GALVANIZED TYPE G 1/2" X 1/2" 19 GAUGE
 - INSECT TYPE I 18X14 ALUMINUM MESH

L#	QUANT.	OPENING SIZE		FRAME	MULL.	SECTIONS WIDE	SCREENS	LOCATION
		WIDTH	HEIGHT					
L-1								
L-2								
L-3								
L-4								
L-5								
L-6								
L-7								

McGILL LOUVERS

1734 Orangebrook Crt. (905) 420-0485 TEL.
 Pickering Ontario (905) 420-4564 FAX
 CANADA (888)-624-4557 TEL.
 L1W 3G8 (888)-624-4558 FAX
 EMAIL : engineering@the-mcgill-group.com

FINISHES

COLOUR # _____

- MILL FINISH
- 5000 SERIES AAMA -603 BAKED ENAMEL
- 10000 SERIES AAMA -605.2 KYNAR 2 COAT
- 15000 SERIES AAMA -605.2 KYNAR 3 COAT
- CLEAR ANODIZING .0004 .0007
- COLOUR ANODIZING _____

PROJECT _____

ARCH/ENG. _____

CONTRACTOR _____

REPRESENTATIVE _____

SCALE _____ DATE _____

SHEET _____

OF _____